



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 28/08/2026

Shift: B

Incharge(s): Saurabh Kumar Yadav,P Venkat Kiran,P Venkat Kiran

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	co-25	olr tripped	reset done	16:45:00 21:50:00	16:55:00 22:00:00	
2	OHP	wobr-3 on co-25	It no taking place, m4 tripped due to track jamming	informed operation and reset done.	17:35:00	17:50:00	
3	CHP	CC 52	mpd tripped	reset	14:30:00	14:35:00	3 times