



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 01/05/2026

Incharge(s): Nagendra Midde

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 25	OLR ACTED	RESET	05:20:00	05:30:00	
2	OHP	WBR ON CO 6A	BREAKER TRIPPED	MADE IT ON	03:00:00	03:20:00	
3	OHP	CO 26	OLR ACTED	RESET	02:00:00	05:10:00	3 TIMES
4	CHP	SCR 8 ON CC 112	LT PCRD MPCB TRIPPED	MADE IT ON	23:55:00	00:10:00	
5	CHP	SCR 6 ON CC 40 LT	O/T ACTED	RESET	01:00:00 01:50:00	01:10:00 02:00:00	
6	CHP	SCR 3 ON CC 37 LT	O/T ACTED DUE TO CABLE ZIG ZAG , GUDE PROBLEM	AFTER MECH CLEARANCE WINDING DONE	02:50:00	03:00:00	
7	CHP	CC 131	OLR ACTED	RESET	04:40:00	04:45:00	
8	CHP	CC 51	FEEDING CONV OLR ACTED	RESET	03:40:00	03:45:00	
9	CHP	CC 27A T/T	MPCB TRIP	MADE IT ON	22:30:00	22:35:00	
10	WT	OP4	D2 OLR ACTED	RESET	03:30:00	03:40:00	