



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 25/07/2026

Area: OHP

Equipment	Job
co-5a tbs	boom run signal latch is done in program and indication provided in OCR HMI.
co-5a tbs	boom run signal latch is done in program and indication provided in OCR HMI.
tt-2 and tt-3	chute vibrators auto operation is checked and found ok.
tt-2 and tt-3	chute vibrators auto operation is checked and found ok.