



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 25/07/2026

Shift: B

Incharge(s): Amit Roy,K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	co-19	REPORTED B/S NOT HEALTHY FOUND B/S ACTED	RELEASED THAN OK	14:40:00	14:50:00	
2	OHP	WOBR ON CO-25	REPORTED LT NOT TAKING PLACE PCRD O/T ACTED (2TIMES)	RELEASED	15:10:00 18:10:00	15:20:00 18:25:00	
3	OHP	CO-26	OLR ACTED(2TIMES)	RESET DONE	19:25:00 20:30:00	19:30:00 20:35:00	
4	CHP	WOBR ON CO-26	REPORTED ALL DRIIVES NOT RUNNING FOUND LUFF DOWN EMG LIMIT ACTED	LIMIT RELEASED THAN OM	17:40:00	18:00:00	
5	CHP	CC-51	MPD TRIP (FEEDING CONVEYOR STOP)	RESET DONE	16:55:00	17:10:00	
6	CHP	CC-52	MPD TRIP (FEEDING CONVEYOR)	RESET DONE	17:00:00 21:35:00	17:10:00 21:40:00	
7	CHP	CC-58	TRIP ON CURRENT SP FAULT	RESET DONE	20:15:00	20:30:00	
8	CHP	CC-201	OLR ACTED	RESET DONE	17:20:00	17:30:00	
9	CHP	CC-28	OLR ACTED	RESET DONE	19:20:00	19:30:00	