वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 08/11/2026

Shift: A

Incharge(s): Saurabh Kumar Yadav

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	vf 10a	olr acted	reset	12:30:00	12:40:00	
2	OHP	op5	no power,i/c tripped @ col no 51	made on,checked near pusher nothing found	07:50:00	08:00:00	
3	OHP	VF2	mpcb tripped	reset	13:20:00	13:25:00	
4	OHP	BRC on co 33 M	LT is not working	checked all ok,wrong complaint	08:30:00	08:45:00	
5	OHP	co 26	olr acted	reset	12:35:00	12:40:00	
6	CHP	CC 51	mpd tripped	reset	08:35:00	08:40:00	
7	CHP	CC 131	olr acted	reset	10:05:00	10:10:00	
8	CHP	cc 54	OLR ACTED	reset	09:50:00	09:55:00	2 times
9	CHP	CC 111 scr 4	pcrd problem,guide problem	informed mech	08:00:00	08:10:00	
10	CHP	CC 32 scr5	LT not working,emergency Pb acted	released	10:00:00	10:10:00	
11	WT	cp 4	no fwd movement,fwd lmt acted	released	06:10:00	06:20:00	
12	WT	OP5	no power,acb tripped @ col no 90	made it on,checked pusher no spark observed	09:25:00	09:45:00	to be checked trolley line
13	WT	OAF 1A,2A and OC1A	reported red	PLC power recycle done	09:30:00	09:40:00	to be checked