



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 07/09/2026

Area: WT

Equipment	Job
CP 4 jobs	#power cable termination done @panel for all drives D1to D3 motor alignment done and termination done # D1 to D3 ,DBU and DBR termination done # Mast fixing and cable laying done ,panel side terminated
CP 1	Panel and Motor side ppm done
CP 3	Panel and Motor side ppm done,phase indicator lamps replaced