



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 06/09/2026

Incharge(s): G Eswara Rao

Shift: C

| Sl No | Area | Equipment | Problem               | Action                | From                             | To                               | Remarks |
|-------|------|-----------|-----------------------|-----------------------|----------------------------------|----------------------------------|---------|
| 1     | OHP  | CO 34     | TRIPPED ON OLR/3TIMES | RESET ODNE            | 00:30:00<br>00:55:00<br>23:40:00 | 00:35:00<br>01:00:00<br>23:45:00 |         |
| 2     | OHP  | CO 26     | TRIPPED ON OLR        | RESET DONE            | 01:00:00                         | 01:05:00                         |         |
| 3     | OHP  | CO 25     | TRIPPED ON OLR        | RESET DONE            | 04:20:00                         | 04:25:00                         |         |
| 4     | CHP  | CC 58     | TRIPPED ON SP FAULT   | RESET DONE            | 23:25:00                         | 23:45:00                         |         |
| 5     | CHP  | CC 202    | PC ACTED              | RESET DONE            | 05:00:00                         | 05:15:00                         |         |
| 6     | CHP  | CC 201    | TRIPPED ON OLR        | RESET DONE            | 04:30:00                         | 04:40:00                         |         |
| 7     | WT   | CP 3      | F/R NOT TAKING PLACE  | E-STOP ACTED/RELEASED | 04:00:00                         | 04:10:00                         |         |