



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 03/09/2026

Incharge(s): G Eswara Rao

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	BRC ON CO 8A	NO DRIVES RUNNING/ACB TRIPPED	ACB MADE ON THEN OK	16:40:00	17:00:00	
2	OHP	VF 21	MPCB KEPT OFF DUE TO JAMMING	AFTER CLEARENCE MPCB MADE ON	17:30:00	18:00:00	
3	CHP	CC 131	TRIPPED ON OLR	RESET DONE	18:15:00	18:25:00	
4	CHP	CC 132	PC ACTED/	RESET DONE	14:40:00	14:50:00	
5	CHP	SCR 2 ON CC33	LT NOT TAKING PLACE PCRD ZSS ACTED	RESET DONE	19:50:00	20:05:00	
6	WT	OP 2	F/R NOT TAKING PLACE/M3 OLR ACTED	RESET DONE	18:15:00	18:30:00	
7	WT	CO 4 C/D	TRIPPED ON OLR	RESET DONE	14:40:00	14:50:00	
8	WT	OT 4	HYDROLIC PUMP 1 NOT RUNNING/Y PHASE GOT BURNT IN MOTOR TB	SELECTION CHANGED TO PUMP 2	18:50:00	19:00:00	FOR AVOID TIPLING DELAY