



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 25/09/2026

Shift: A

Incharge(s): Saurabh Kumar Yadav

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	wobr on co 6A	LT not working,s/s in local	kept in remote	06:25:00	06:40:00	
2	OHP	wobr on co 6A	b/c not running,mccb tripped,	megger done found 0.1 mohm,hot blowing done ,contactor insulation provided,v1 and w1 lead	09:00:00	12:30:00	trial run taken given clearance
3	OHP	co 26	olr acted	reset	10:05:00	10:15:00	
4	OHP	co 21	zss acted,probe wire got cut	wire connected	11:45:00	12:10:00	
5	OHP	tbs on co24	LT not working,s/s in local	kept in remote	12:35:00	12:50:00	
6	OHP	TBS on CO 21	LT not working,m3 olr acted	reset	13:00:00	13:20:00	
7	IOSA	brc	b/w 2 not running,zss acted	sensitivity adjusted	09:20:00	09:40:00	