



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 25/07/2026

Incharge(s): Amit Roy,K SANKARA RAO

Shift: B

| Sl No | Area | Equipment     | Problem                                                          | Action                 | From                 | To                   | Remarks |
|-------|------|---------------|------------------------------------------------------------------|------------------------|----------------------|----------------------|---------|
| 1     | OHP  | co-19         | REPORTED B/S NOT HEALTHY FOUND B/S ACTED                         | RELEASED THAN OK       | 14:40:00             | 14:50:00             |         |
| 2     | OHP  | WOBR ON CO-25 | REPORTED LT NOT TAKING PLACE PCRD O/T ACTED (2TIMES )            | RELEASED               | 15:10:00<br>18:10:00 | 15:20:00<br>18:25:00 |         |
| 3     | OHP  | CO-26         | OLR ACTED(2TIMES)                                                | RESET DONE             | 19:25:00<br>20:30:00 | 19:30:00<br>20:35:00 |         |
| 4     | CHP  | WOBR ON CO-26 | REPORTED ALL DRIIVES NOT RUNNING FOUND LUFF DOWN EMG LIMIT ACTED | LIMIT RELEASED THAN OM | 17:40:00             | 18:00:00             |         |
| 5     | CHP  | CC-51         | MPD TRIP (FEEDING CONVEYOR STOP )                                | RESET DONE             | 16:55:00             | 17:10:00             |         |
| 6     | CHP  | CC-52         | MPD TRIP (FEEDING CONVEYOR)                                      | RESET DONE             | 17:00:00<br>21:35:00 | 17:10:00<br>21:40:00 |         |
| 7     | CHP  | CC-58         | TRIP ON CURRENT SP FAULT                                         | RESET DONE             | 20:15:00             | 20:30:00             |         |
| 8     | CHP  | CC-201        | OLR ACTED                                                        | RESET DONE             | 17:20:00             | 17:30:00             |         |
| 9     | CHP  | CC-28         | OLR ACTED                                                        | RESET DONE             | 19:20:00             | 19:30:00             |         |