



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 25/07/2026

Shift: C

Incharge(s): G Eswara Rao

| Sl No | Area | Equipment      | Problem                                                   | Action                           | From     | To       | Remarks |
|-------|------|----------------|-----------------------------------------------------------|----------------------------------|----------|----------|---------|
| 1     | OHP  | VS 3A          | TRIPPED ON OLR                                            | RESET DONE                       | 05:10:00 | 05:20:00 |         |
| 2     | OHP  | CO 8           | HEALTHY STOP WHILE RUNNING/LOOSE AT SOFT RELAY TERMISSION | TIGHTENED                        | 02:05:00 | 02:05:00 |         |
| 3     | OHP  | TBS ON CO 21   | LT NOT TAKING PLACE/PCRD CABLE TENSION ACTED              | TENSION RELEASED                 | 23:25:00 | 23:40:00 |         |
| 4     | OHP  | BRC ON CO 30   | LT NOT TAKING PLACE/DRIVE TRIPPED                         | RESET DONE                       | 23:40:00 | 23:55:00 |         |
| 5     | OHP  | WOBR ON CO 6A  | NO DRIVES RUNNING/ACB TRIPPED                             | ACB MADE ON                      | 01:25:00 | 01:45:00 |         |
| 6     | OHP  | TBS ON CO 21   | LT NOT RUNNING/SELECTOR IN LOCAL MODE                     | KEPT IN REMOTE MODE              | 02:08:00 | 02:15:00 |         |
| 7     | OHP  | CO 84          | BRS ACTED/(JOD )                                          | RESET DONE                       | 04:00:00 | 04:15:00 |         |
| 8     | CHP  | TT ON CC58     | LT NOT TAKING PLACE/OLR ACTED                             | RESET DONE                       | 03:40:00 | 04:00:00 |         |
| 9     | CHP  | CC 48          | ZSS ACTING/CAGE BEARINGS PROBLEM                          | ZSS CAGE REPLACED                | 22:00:00 | 22:45:00 |         |
| 10    | CHP  | SCR 9 ON CC213 | BW NOT RUNNING/MCCB TRIPPED                               | MCCB MADE ON                     | 02:45:00 | 02:55:00 |         |
| 11    | CHP  | SCR 7 ON CC 40 | BC NOT RUNNING/OLR ACTED                                  | RESET DONE                       | 02:50:00 | 03:05:00 |         |
| 12    | CHP  | SCR 7 ON CC40  | SLEW NOT TAKING PLACE/30 DEGREE LIMIT ACTED               | RESET DONE                       | 03:25:00 | 03:40:00 |         |
| 13    | CHP  | SCR 2 ON CC33  | BC NOT RUNNING                                            | DIDNT FOUND ANY PROBLEM TESTD OK | 00:50:00 | 01:30:00 |         |



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 25/07/2026

Incharge(s): G Eswara Rao

Shift: C

| Sl No | Area | Equipment | Problem                                                | Action     | From     | To       | Remarks |
|-------|------|-----------|--------------------------------------------------------|------------|----------|----------|---------|
| 14    | WT   | OP 5      | F/R NOT TAKING PLACE/D 5 TRIPPED ON OLR WHILE COUPLING | RESET DONE | 23:30:00 | 23:40:00 |         |