



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 30/08/2026

Incharge(s): Saurabh Kumar Yadav

Shift: B

| Sl No | Area | Equipment      | Problem                                         | Action                 | From     | To       | Remarks |
|-------|------|----------------|-------------------------------------------------|------------------------|----------|----------|---------|
| 1     | OHP  | co 26          | olr acted                                       | reset                  | 18:20:00 | 18:30:00 |         |
| 2     | OHP  | CO 5A          | brs acted due to dust                           | sensor cleaned than ok | 20:10:00 | 20:20:00 |         |
| 3     | CHP  | CC 111 and 112 | yard conveyor stoped due to ACB tripped in CM36 | made it on             | 18:40:00 | 18:50:00 |         |
| 4     | CHP  | CC 52          | mpd acted                                       | reset                  | 15:15:00 | 15:20:00 | 2 times |
| 5     | CHP  | CC 54          | olr acted                                       | reset                  | 15:40:00 | 15:50:00 |         |
| 6     | CHP  | CM 36          | main ACB tripped                                | made it on             | 18:50:00 | 19:00:00 |         |