RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL GENERAL SHIFT REPORT

वी.एस.पी
VSP

Date: 24/10/2026

Area: OHP

Equipment	Job
vfd data and field safety devices in ohp yard	inspection is done.
io panel of yard machines	inspection is done.
om-16	lighting is improved
af-14 motor	motor is run from af-8 panel in decoupled condition,
co-28,27a,30a,32a,34a,36a,36b ; vf1 to vf10	motor and panel side ppm is done. vf-1 to vf-10 spare motor is shifted to VF level.
sump pumps inspection	lc-6,ocr telecom room, locp2 mcc,om10 ; co-5 ,1a tunnel , lc-7, lc-5,lc-3,1-141lc3,lbds-4 and 5 is done
vf-21 both motors	feed rate is decreased from 80 to 70%
vs-2 removed motor	motor base welding is done.
co-11a h/e hoist	pendant replaced and hoist control checking is under progress.