



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 09/07/2026

Shift: C

Incharge(s): Nagendra Midde, G Eswara Rao

| Sl No | Area | Equipment      | Problem                                                                            | Action                                                                             | From     | To       | Remarks                     |
|-------|------|----------------|------------------------------------------------------------------------------------|------------------------------------------------------------------------------------|----------|----------|-----------------------------|
| 1     | OHP  | TBS ON CO-24   | HT power problem. Two HT fuses blown. Checked and found fixed coupler Head problem | After DNW work, charged and given clearance                                        | 22:00:00 | 23:20:00 |                             |
| 2     | OHP  | BRC-1 ON CO-28 | Boom conveyor not stating. Overload acted                                          | Reset done                                                                         | 03:15:00 | 03:25:00 |                             |
| 3     | OHP  | CO-1A          | Pullcord not acted but showing pullcord acted                                      | bypassed and checked pullocrds. Found pullcord acted. Released and kept in circuit | 00:20:00 | 00:40:00 | Not reset done by operation |
| 4     | CHP  | CC-125         | Overload trip                                                                      | Reset done                                                                         | 00:10:00 | 00:15:00 |                             |
| 5     | CHP  | CC-107         | Overload trip                                                                      | Reset done                                                                         | 03:35:00 | 03:40:00 |                             |
| 6     | CHP  | CC-54          | Tripped on Overload                                                                | Reset done                                                                         | 02:20:00 | 02:25:00 |                             |
| 7     | CHP  | CC-107         | Overload acted                                                                     | Reset done                                                                         | 05:35:00 | 05:40:00 |                             |