



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 28/06/2026

Incharge(s): Nagendra Midde

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 48	OLR ACTED	RESET	08:25:00	08:30:00	
2	OHP	CO 26	OLR ACTED	RESET	09:05:00	09:15:00	
3	OHP	BRC ON CO 32	B/W OIL TEMP AND ACC PRESSURE B/W2 ACTED	INFORMED TO MECH	11:00:00	11:20:00	
4	OHP	CO 19 TBS	CHUTE SENSOR PROBE ALIGNMENT PROBLEM	ADJUSTED	07:50:00	08:05:00	
5	OHP	CO 19 TBS	CHUTE SENSOR NEUTRAL MISSING	RECONNECTED PROPERLY	08:20:00	08:40:00	
6	CHP	CC 29 ZSS ACTING	MODULE PROBLEM	REPLACED	07:45:00	08:05:00	
7	CHP	SCR 9 ON CC 106	PCRD CABLE FELL DOWN	WINDING DONE PROPERLY	10:00:00	10:30:00	
8	CHP	CC 43	OLR ACTED	RESET	12:50:00	13:00:00	
9	WT	OT3	D2 FAULT	RESET	08:40:00	08:45:00	