



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 27/06/2026

Incharge(s): Nagendra Midde

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	WBR ON CO 6A	B/C CONTACTOR GOT STUCK	MADE IT FREE CHECKED AND GIVEN CLEARANCE	07:00:00	07:30:00	
2	OHP	CO 35 P/C	CABLE GOT NEAR CHUTE 1	REJOINED	07:30:00	07:45:00	
3	CHP	SCR 10 ON CC 105 LT	PCRD O/T ACTED	RELEASED	09:15:00	09:25:00	
4	CHP	CC 43	OLR ACTED	RESET	10:25:00	10:50:00	
5	CHP	SCR 9 ON CC 106	B/C DISCHARGE CHUTE ACTING DUE TO RAIN	BYPASSED	11:15:00	11:30:00	