



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 06/10/2026

Area: CHP

Equipment	Job
CC 109	PPM was done and damaged finger contacts and jumpers replaced
CC 132	200mts of 5*1.5 Cu cable laid from MD to CJB and cable dressing done
SCR 8	Interlock cage ckt problem rectified and tested
CM 17	Surrounding area cleaning done
CC 217	Control module replaced and found healthy
S 1	LT end limit kept in ckt
Coal complex	Rooms cleaning done
CC 45 T/E	BSS handles provided
CC 111,112	Tail end BSS replaced and kept in ckt
CC 43,48,49,215,218,220,222	PPM was done