



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 08/07/2026

Incharge(s): P Venkat Kiran,P Venkat Kiran

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	LC-8,LC-7,L C-6,LC-5,L C-4,LC-3,1- 141LC4	I/C-2 LT side ACB	BUSCOUPLERS made OFF AND I/C-2 made ON.	14:30:00	15:30:00	OHP all LC incomers normalised.