वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 24/10/2026

Shift: B

Incharge(s): Nagendra Midde

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 34	OLR acted	Reset	17:55:00	18:05:00	
2	OHP	TBS on co 7a Luff	Drive Trip	Reset	17:10:00	17:20:00	
3	OHP	VS 10a	M1 trip	Reset	18:00:00	19:00:00	2 times
4	CHP	CC 51	Feeding conv OLR acted	Reset	15:55:00	16:00:00	2 Times
5	CHP	CC 131	OLR acted	Reset	17:50:00	17:55:00	
6	CHP	CC 25	OLR acted	Reset	14:10:00	15:55:00	2 times
7	CHP	CC 219 ZSS	Module Problem	Replaced	14:45:00	15:00:00	
8	CHP	CC 107	OLR acted	Reset	20:35:00	20:40:00	
9	CHP	CC 125	OLR acted	Reset	20:55:00	21:00:00	
10	CHP	SCR 9 on CC 104 Slew	MCCB tripped	Reset	20:50:00	21:05:00	