



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 28/04/2026

Incharge(s): Nagendra Midde

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 26	OLR ACTED	RESET	22:50:00	05:00:00	4 TIMES
2	OHP	BRC ON CO 28	B/W 1 IRON PLATE STUCK	INFORMED TO MECH	00:50:00	01:10:00	
3	CHP	CC 51	FEEDING CONV OLR ACTED	RESET	23:55:00	00:00:00	
4	CHP	SCR 7 ON CC 39 LT	PCRD CABLE ZIG ZAG	WINDING DONE PROPERLY	01:50:00	02:20:00	
5	CHP	SCR 7 ON CC 39 LT	DRIVE TRIPPED	RESET	04:10:00	05:20:00	3 TIMES