



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 25/04/2026

Incharge(s): Saurabh Kumar Yadav

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	tbs on co 5A	LT not working,pcrd Ot acted	OT released	15:10:00	15:25:00	
2	OHP	TBS on co 24	LT not working,M4 mpcb tripped,brake problem	made it on	15:40:00	15:50:00	mech adjusted brake
3	OHP	CO 26	OLR acted	reset	20:30:00	20:40:00	
4	OHP	wobr on co 29	slewing not working,drive tripped	reset	20:30:00	20:45:00	
5	OHP	BRC on CO 28	B/W 2 not running,chain got side line from gear teeth	mechanical problem	20:55:00	21:10:00	
6	OHP	VF 19	mpcb tripped,base bolt damaged	base bolt replaced	20:00:00	21:30:00	
7	CHP	CC 112 scr 8	b/c not working,zss cage stucked in coal	cage cleared	18:05:00	18:15:00	
8	CHP	CC 13	zss acted,coal stucked in cage	cage made free	17:30:00	17:45:00	
9	WT	AF 4 ore	drive tripped in speed deviation fault	reset	17:50:00	17:55:00	