



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 24/04/2026

Area: WT

Equipment	Job
OP-9	PANEL AND MOTOR SIDE PPM DONE
OT-5	SERIES MOTOR SIDE PPM DONE
DE-1	FAN CONTACTOR AND RELAY CHANGED AND TESTED
CP-3 AND CP-4	TROLLEY LINE INSPECTION DONE
CT-1 AND CT-2	SERIES PPM DONE