



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 24/04/2026

Incharge(s): G Eswara Rao

Shift: A

| Sl No | Area | Equipment      | Problem                   | Action                      | From     | To       | Remarks |
|-------|------|----------------|---------------------------|-----------------------------|----------|----------|---------|
| 1     | OHP  | WBR 3 ON C0 26 | HT OLD JOINT GOT OPENED   | AFTER DNW CLEARANCE CHARGED | 07:00:00 | 11:30:00 |         |
| 2     | OHP  | CO 25          | OLR ACTED                 | RESET                       | 08:20:00 | 08:30:00 |         |
| 3     | OHP  | CO 34 B/C      | ALL CONNECTIONS TIGHTENED | THEN OK                     | 12:25:00 | 12:45:00 |         |
| 4     | WT   | OP4            | DRIVE 3 TRIPPED           | RESET                       | 11:00:00 | 11:15:00 |         |