



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 24/04/2026

Incharge(s): Amit Roy

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-3A	ZSS acted	Cage struck up.Made free and tested okay	23:15:00	23:35:00	
2	OHP	BRC on CO-28	B/W-2 tripped	OLR acted.Reset done	05:40:00	05:55:00	
3	OHP	VF-19	Reported tripped	MPCB tripped.CHP side motor base bolts sheared.Replaced with new base bolts and tested okay	04:30:00	05:00:00	
4	CHP	CC-40 S2	Lt not taking place	Wrong complaint	04:00:00	04:10:00	
5	CHP	CC-51	MPD tripped	Reset done	02:50:00	02:55:00	
6	WT	OP-7	Reported not moving	LS-1 sensor contact not coming.Bypassed and tested okay	04:10:00	04:20:00	