



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 12/07/2026

Incharge(s): K SANKARA RAO

Shift: A

| Sl No | Area | Equipment      | Problem                                                           | Action                                                          | From     | To       | Remarks |
|-------|------|----------------|-------------------------------------------------------------------|-----------------------------------------------------------------|----------|----------|---------|
| 1     | OHP  | CO-7           | OLR ACTED                                                         | RESET DONE                                                      | 12:25:00 | 12:50:00 |         |
| 2     | CHP  | CC-215         | OLR ACTED (4TIMES)                                                | RESET DONE                                                      | 07:50:00 | 10:40:00 |         |
| 3     | CHP  | CC-107         | OLR ACTED                                                         | RESET DONE                                                      | 12:45:00 | 12:50:00 |         |
| 4     | CHP  | CC-38<br>SCR-6 | REPORTED SLEW AND B/W NOT RUNNING<br>FOUND CP ACTED               | INFORMED TO MECHANICAL                                          | 12:30:00 | 12:45:00 |         |
| 5     | CHP  | CC-40<br>SCR-7 | B/C OLR ACTED                                                     | RESET DONE                                                      | 13:15:00 | 13:20:00 |         |
| 6     | CHP  | CC-52          | MPD TRIP                                                          | RESET DONE                                                      | 13:35:00 | 13:40:00 |         |
| 7     | CHP  | SCR-7          | MODEM REMOVED FROM SCR-9 IN NIFHT<br>KEPT IN SCR-7 .. DIDNOT WORK | MODEM REMOVED FROM S-3 IN R-BAY AND<br>KEPT IN SCR-7 AND TESTED | 08:00:00 | 09:30:00 |         |