RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL GENERAL SHIFT REPORT

Date: 10/11/2026

Area: WT

Equipment	Job
MIS	2 nos faulty modems checked and one modem rectified by LOTUS
MIS	37 KW spare pusher motor coupling fixed
OP 5	Trolley line inspection done,col no 15 cable fault rectified
CP 1	Motors greasing done
OT 5 series	Motors greasing done
OT 4 series	Motor side ppm done