



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 11/07/2026

Shift: A

Incharge(s):

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-29	TRIPPED ON OLR	RESET DONE	06:45:00	06:55:00	
2	OHP	CO-25	TRIPPED ON OLR	RESET DONE	07:00:00	07:10:00	
3	OHP	CO-50	OLR ACTED	RESET DONE	07:00:00	07:20:00	
4	OHP	CO-28 BRC	LT NOT WORKING PCRD OT	RECTIFIED	07:50:00	08:15:00	
5	OHP	CO-28 BRC	BC OLR ACTED	RESET DONE	09:50:00	10:05:00	
6	OHP	CO-25 WBR	PCRD OT ACTED	RELEASED	11:15:00	11:30:00	
7	OHP	CO-32 BRC	HYD PUMP TRIPPING IN P-F	CHECKING GOING ON	13:15:00	14:00:00	
8	CHP	CC-112 SCR-5	LT M-5 MOTOR TRIP	RESET DONE	08:00:00	08:13:00	
9	CHP	CC-105 SCR-10	PUMP TRIP IN LOW CHARGE PRESSURE	RESET DONE	09:10:00	09:20:00	
10	CHP	CC-215	OLR TRIPPED	RESET DONE	12:30:00	12:40:00	
11	CHP	CC-213 SCR-9	SLEW NOT WORKING	LIMIT ACTED .. RELEASED	13:15:00	13:35:00	