



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 19/08/2026

Incharge(s): G Eswara Rao

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	co 49 ON CO20	CHUTE VIBRATOR power mpcb tripped, motor bearing stucked	made it off	04:15:00	04:40:00	to be replaced
2	CHP	CC 50	ZSS ACTING DUE TO OVER MATERIAL/BELT LOW SPEED	INFORM TO OPE.	02:50:00	03:05:00	
3	CHP	CC 51	MPD TRIPPED ON OLR	RESET DONE	22:30:00	22:40:00	
4	CHP	CC 131	TRIPPED ON OLR	RESET DONE	02:40:00	02:45:00	
5	IOSA	L and T woblr	Lt not taking place,OT acted	OT released	03:10:00	03:20:00	