



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 15/07/2026

Shift: C

Incharge(s): Amit Roy,K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	wobr on co-25	It not taking place pcrd o/t acted	released	00:00:00	00:15:00	
2	OHP	CO-26	OLR ACTED (2TIMES)	RESET DONE	01:00:00 04:15:00	01:10:00 04:30:00	
3	OHP	Daybin-1 compressor	Reported not running	Oil filled by mechanical.Tested okay	00:43:00	00:57:00	
4	OHP	RSCO-1A	Reported not healthy	Checked and found BRS acted.Reset done and tested okay	23:55:00	00:04:00	
5	CHP	CC-52	REPORTED STOPPING ON ZSS FOUND NO ELECTRICAL PROBLEM GEAR BOX PROBLEM	INFORMED TO MECHANICAL	05:00:00	05:10:00	
6	CHP	CC-51	MPD TRIP (3TIMES)	RESET DONE	05:30:00	05:45:00	
7	CHP	CC-110	REPORTED STOPPING ON ZSS DUE TO MATERIAL OVER LOAD	CLEARANCE GIVEN THAN OK	00:30:00	00:40:00	
8	CHP	CC-112 S-3	B/C not running	MPR tripped.Reset done	22:30:00	22:46:00	
9	CHP	CC-112 S-3	B/C not running	Signal missing.LT done and tested okay	00:30:00	00:40:00	
10	CHP	CC-41	Reported tripped	OLR acted.Reset done	03:28:00	03:40:00	
11	CHP	CC-201,203	Reported tripped	OLR acted.Reset done	05:45:00	05:55:00	