



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 16/06/2026

Incharge(s): G Eswara Rao

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 84	ELECTRICAL BRS MALFUNCTIONING/2TIMES	BYPASSED AT MODULE	07:00:00	07:30:00	NO DELAY/TO BE KEPT IN CKT
2	OHP	CO 26	TRIPPED ON OLR 3TIMES	RESET DONE	07:05:00 08:50:00	07:10:00 08:55:00	
3	OHP	BRC 2 ON CO 30	BC CJD WAS BYPASSED IN C SHIFT	CJD KEPT IN CKT	06:40:00	07:00:00	NO DELAY
4	CHP	CC 29	ZSS ACTING/CAGE STUCKUP WITH MATERIAL	ZSS CAGE MADE FREE	07:30:00	07:40:00	
5	CHP	CC 54	TRIPPED ON OLR	RESET DONE	12:35:00	12:45:00	
6	CHP	SCR 1 ON CC 31	BOOM LUFFING UP and DOWN TRIPPING FREQUENTLY IN DOWN CUTTING	RESET DONE	06:45:00 12:45:00	07:00:00 13:15:00	TO BE CHECKED MECH and ELECT.