



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 21/05/2026

Incharge(s): Lal Singh

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	VS-1A	OLR ACTED	RESET DONE	16:25:00	16:35:00	
2	CHP	CC-37 SCR-3	LUFF NOT WORKING ... OIL LOW	INFORMED MECH	17:50:00	18:00:00	
3	CHP	CC-125	MPD TRIPPED	RESET DONE	18:10:00	18:20:00	
4	CHP	CC-44	TRIOPPED ON OLR	RESET DONE	20:15:00	20:25:00	
5	CHP	CC-104 SCR-6	LT MPCB M-2 ACTED	RESET ... INFORMED FOR TRACK CLEANING	20:50:00	21:10:00	
6	CHP	CC-51	MPD TRIP	RESET DONE	16:05:00 17:25:00	16:10:00 17:30:00	
7	CHP	CC-52	MPD TRIPPED 3 TIMES	RESET DONE	17:30:00	20:00:00	
8	CHP	CC-15	CJD ACTING	CHECKED NO ELECTRICAL PROBLEM FOUND	21:00:00	21:20:00	
9	WT	CO-3	HIGH MOTOR TEMP	FAN FIXED	21:30:00	22:00:00	