



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 28/09/2026

Area: OHP

Equipment	Job
co-9a brs ; co-42a,43a brs ; co-11a pullchord	restored in circuit
brc-3 on co-34	shifted from co-34 to 33m
wbr-4 on co-6a	LT M8 motor coupling welded and checked. m6 motor to be replaced. m6 gearbox issue informed mechanical.
brc-4 on co-8a	oil cooler fan mpcb is tripping, checking under progress
co-35a brs	shifted towards head end on operation requirement