



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 01/05/2026

Shift: A

Incharge(s): Saurabh Kumar Yadav

| Sl No | Area | Equipment                     | Problem                                          | Action               | From     | To       | Remarks |
|-------|------|-------------------------------|--------------------------------------------------|----------------------|----------|----------|---------|
| 1     | OHP  | co 26                         | olr acted                                        | reset                | 07:05:00 | 07:15:00 | 4 times |
| 2     | OHP  | wobr on co 25                 | slewing not working,drive tripped                | reset                | 06:35:00 | 06:50:00 |         |
| 3     | OHP  | BRC on CO 32                  | bc not running,emergency acted near e house      | emergency released   | 07:20:00 | 07:40:00 |         |
| 4     | OHP  | BRC on CO 28                  | bc not running,olr acted                         | reset                | 09:45:00 | 09:55:00 |         |
| 5     | CHP  | cc 31                         | slew not working,drive tripped                   | reset                | 06:50:00 | 07:00:00 |         |
| 6     | CHP  | CC 33 SCR2                    | Lt not working,wrong complaint                   | checked found all ok | 07:40:00 | 07:50:00 |         |
| 7     | CHP  | CC 33 SCR2                    | slew not working,left limit acted due to jamming | informed operation   | 07:50:00 | 08:00:00 |         |
| 8     | CHP  | CC 107                        | olr atced                                        | reset                | 09:00:00 | 09:05:00 |         |
| 9     | CHP  | CC 31,32 and 33 yard conveyor | not healthy,acb tripped in LC17                  | made it on           | 11:05:00 | 11:15:00 |         |
| 10    | CHP  | C C 51                        | mpd acted                                        | reset                | 09:05:00 | 09:10:00 |         |
| 11    | WT   | OP7                           | no fwd movement,ls1 and 2 acted in OT4           | ls1 and 2 bypass     | 08:45:00 | 08:58:00 |         |
| 12    | WT   | OP 4                          | no movement,D2 olr acted @ coupling time         | reset                | 10:10:00 | 10:20:00 |         |