



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 12/08/2026

Incharge(s): P Venkat Kiran,P Venkat Kiran

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 25	TRIPPED ON OLR/4TIMES	RESET DONE	07:35:00 08:55:00 12:40:00	07:45:00 09:05:00 12:45:00	
2	CHP	CC 54	MPD TRIPPED ON OLR/5TIMES	RESET DONE	10:30:00	11:40:00	
3	CHP	CC 40	MPD TRIPPED ON OLR	RESET DONE	08:00:00	08:05:00	