



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 20/08/2026

Incharge(s): Saurabh Kumar Yadav, G Eswara Rao

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	WOBR ON CO 6A	FAULT RESET PB STUCKUP/	PB REPLACED	01:10:00	01:25:00	
2	OHP	CO 29	TRIPPED ON OLR	RESET DONE	03:20:00	03:30:00	
3	OHP	CO 25	TRIPPED ON OLR	RESET DONE	04:50:00	05:00:00	
4	CHP	CC 131	TRIPPED ON OLR	RESET DONE	01:15:00	01:20:00	
5	CHP	SCR 7 ON CC40	MPD TRIPPED ON OLR	RESET DONE	02:25:00	23:00:00	