



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 05/09/2026

Area: CHP

Equipment	Job
CC 130	Motor replaced,alignment done.Trail run pending
CC 7,15	PPM was done
CC 222 gallery	3 nos 70W SV fixtures arranged
SCR 7	Lighting cable jointed inside the chamber and restored lighting
CC 37	Burnt motor coupling removed and sent to ERS
CC 40,107,SCR 7,CC216,218,220,222	PPM was done