



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 05/09/2026

Area: OHP

Equipment	Job
brc-4 on co-8a	HT slip ring maintenance was done.
vf-15a chute vibrator	chute vibrator motor was found hanging, fixed back in place and trail run is taken
TBS on co-5A	Boom Run FB and CJD bits at the TBS RMU were interchanged, and the corresponding changes were also incorporated in the Siemens PLC program.
BRC-3 on co-33m	shifted from co-33m to co-34