



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 04/09/2026

Area: CHP

Equipment	Job
CC 19	PC kept in ckt
LC 15 cellar	8 nos tube fixtures provided
CC 13/14 gallery	Ckt problem rectified and improved lighting
RG 3,VS 3,VF 3	PPM was done
LC 18,CM 19	Rooms cleaning done
S1,SCR 6	Inter changed the yard machines
CC 37	Second power cable which was open at motor side, lugs crimped and terminated
CC 37	Motor replaced and trail run was taken