



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 06/07/2026

Incharge(s): K SANKARA RAO

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-16	OLR ACTED	RESET DONE	06:00:00	06:10:00	
2	OHP	co-26	olr ACTED	RESET DONE	10:10:00	10:20:00	
3	OHP	CC-52	MPD TRIP	RESET DONE	10:30:00	10:35:00	
4	CHP	CC-203	OLR ACTED	RESET DONE	07:30:00	07:35:00	
5	CHP	CC-26A	OLR ACTED	RESET DONE	12:40:00	12:45:00	
6	CHP	CC-33 SCR-2	REPORTED LT NOT TAKING PLACE DRIVE TRIP	REST DONE	12:35:00	12:50:00	
7	CHP	CC-215	CJD ACTED DUE TO MOISTURE	CLEANED THAN OK	13:10:00	13:25:00	