



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 15/07/2026

Incharge(s): P Venkat Kiran,P Venkat Kiran

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	tbs-3 on co-21	cjd malfunctioning	bypassed at module and informed instrumentation.	07:00:00	07:15:00	kept in circuit later on.
2	OHP	wobr-3 on co-25	It not taking place	pcrd o/t acted. released done	07:25:00	07:40:00	
3	OHP	wbr-2 on co-29	luff not taking place	luff pump olr acted. reset done	10:15:00	10:30:00	
4	OHP	brc-1 on co-28	bridge conveyor olr acted, due to jamming	reset done	12:00:00	12:15:00	
5	WT	co-4	zss cage rod was damaged	rod replaced and restored its working	12:40:00	12:55:00	