



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 21/09/2026

Shift: B

Incharge(s): Saurabh Kumar Yadav

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	co 26	olr acted	reset	17:30:00	17:35:00	3 times
2	OHP	CO 29	olr acted	reset	21:00:00	21:11:00	
3	OHP	WOBR on CO 25	slew not working left side, limit switch stucked	released	18:35:00	18:50:00	
4	CHP	cc 32	motor mpd tripped	reset	19:05:00	19:15:00	2 times
5	CHP	CC 51 A	tripped due jamming	reset	21:20:00	21:35:00	
6	CHP	CC 131	tripped due to olr	reset	21:40:00	21:45:00	
7	CHP	CC 114	pc acted	released	15:00:00	15:15:00	
8	IOSA	old wobr	LT not working, drive tripped	reset	19:50:00	20:00:00	