



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 22/07/2026

Shift: B

Incharge(s): Amit Roy,K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	co-25	olr acted (2times)	reset done	18:00:00 18:30:00	18:10:00 18:40:00	
2	OHP	TBS ON CO-20	REPORTED L/LUFF NOT WORKING ACB OFF CONDITION	ACB MADE ON THAN OK	18:00:00	18:10:00	
3	OHP	WOBR ON CO-29	SLEW NOT WORKING DRIVE TRIPPED	Reset done but checked and found brake not releasing.Brake loosened and tested okay	18:00:00	18:20:00	
4	OHP	WOBR on CO-25	Reported B/C not running	Checked and found control tripped due to down emergency acted.Bypassed and luff up done and tested okay	19:52:00	20:15:00	
5	CHP	CC-113	REPORTED C/S NOT WORKING CHECKED AND FOUND NO PROBLEM	INFORM TO OPERATION	18:40:00	19:30:00	
6	CHP	CC-131	OLR ACTED	RESET DONE	21:15:00	21:20:00	
7	CHP	CC-24BELT DRIVE	OLR ACTED	RESET DONE	18:30:00	18:40:00	
8	CHP	CC-29	REPORTED STOPPING ON ZSS FOUND ZSS CAGE STUCK UP WITH COAL PICK	REMOVED THAN OK	19:50:00	20:00:00	