



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 26/08/2026

Incharge(s): Nagendra Midde

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 25	Olr acted	Reset	06:00:00	06:10:00	
2	OHP	WBR on co 25	B/W MPCB trip	Made it on	09:05:00	09:20:00	
3	OHP	CO 13	OLR acted	Reset	09:45:00	09:50:00	
4	CHP	SCR 6 on CC 38	B/C OLR acted	Reset	12:45:00	13:00:00	
5	CHP	CC 22 C/D	OLR acted	Reset	10:30:00	10:40:00	
6	CHP	CC 26 a	T/T F/G OLR acted	Reset	11:00:00	11:10:00	