



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 04/09/2026

Incharge(s): Saurabh Kumar Yadav

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 25	OLR ACTED	reset	08:34:00	08:42:00	
2	OHP	co 26	OLR ACTED	reset	10:25:00	10:35:00	2 times
3	OHP	CC 52	mpd acted	reset	13:15:00	13:20:00	
4	OHP	cc 36 s1	slew not working,plc no power,mcb tripped	made it on	06:30:00	06:40:00	
5	CHP	cc 36	cs acted,module no supply,phase wire in open	phase wire connected	06:45:00	06:55:00	