



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 07/07/2026

Area: CHP

Equipment	Job
CC 12,14,18	PPM was done
CC 56/115 gallery	3 nos 350W LED fixtures focused outside towards coke unloading yard
Coal complex	Rooms cleaning done
SCR 9	Slew MCCB trip contact wired to healthy ckt
CC 106 S 2	LT end limit striker welded
CC 106,S2	PPM was done