



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 06/07/2026

Incharge(s): Nagendra Midde

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 25	OLR ACTED	RESET	00:25:00	01:40:00	3 TIMES
2	OHP	BRC ON CO 28	B/C OLR ACTED	RESET	03:00:00	03:15:00	
3	OHP	TBS ON CO 20 LT	PCRD GUIDE PROBLEM	INFORMED TO MECH	04:30:00	04:45:00	
4	CHP	CC 51	FEEDING CONV OLR ACTED	RESET	05:25:00	05:30:00	
5	CHP	CC 117 F/G	OLR ACTED	RESET	23:00:00	23:30:00	
6	CHP	CC 52	FEEDING CONV O;LR ACTED	RESET	05:10:00	05:15:00	
7	CHP	CC 125	OLR ACTED	RESET	22:50:00	23:00:00	
8	CHP	SCR 2 ON CC33 LT	DRUM SENSOR ACTED	RESET	02:55:00	03:10:00	
9	CHP	SCR 9 ON CC213	SLEW MCCB TRIP	MADE IT ON	05:10:00	05:40:00	
10	CHP	WBR ON CO 26 LT	PCRD CABLE STUCK	RELEASED	02:25:00	03:00:00	