RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL GENERAL SHIFT REPORT

वी.एस.पी
VSP

Date: 14/10/2026

Area: OHP

Equipment	Job
tbs-7 on co-19	LT m1 motor installed and trail run is taken.
WOBR-4 on co-6a	pull chord installed, restored in circuit. Old BC ZSS modules removed from site.
co-36,37,47,48	motor , panel, field devices ppm is done. Faulty devices are noted, RSCO-2a BSS circuit checked,.