



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 18/07/2026

Shift: C

Incharge(s): Amit Roy, K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	co-26	olr acted	reset done	22:55:00	23:05:00	
2	OHP	CO-29	OLR ACTED	RESET DONE	00:30:00	00:40:00	
3	CHP	CC-131	OLR ACTED (3TIMES)	RESET DONE	00:15:00	03:15:00	
4	CHP	CC-29 TO CC-111	POSITION SENSOR DAMAGED	BYPASSED	02:20:00	02:30:00	
5	CHP	CC-107	OLR ACTED	RESET DONE	02:50:00	02:55:00	
6	CHP	CC-36, S-1	REPORTED LT NOT TAKING PLACE M-1 TRIP	RESET DONE	05:05:00	05:20:00	