वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 27/10/2026

Shift: A

Incharge(s): G Eswara Rao

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CR 1A	EXTRANAL OIL FLOW ACTED/NO ELECTRIAL PROBLEM	INFORM TO MECH. and OPERATION	10:30:00	10:50:00	
2	OHP	BRC NO CO 32	HYDROLIC PUMP NOT RUNNING/OIL LEVEL LOW NOT RESET ING	INFORM TO OPERATION AND INSTRU.	12:30:00	14:00:00	PENDING TO B SHIFT
3	OHP	CO 26	TRIPPED ON OLR	RESET DONE	09:10:00	09:15:00	
4	OHP	WOBR ON CO 26	SLEW NOT TAKING PLACE/DRIVE TRIPPED ON OLR	RESET DONE	09:50:00	10:05:00	
5	OHP	CO 25	TRIPPED ON OLR	RESET DONE	11:05:00	11:15:00	
6	OHP	BRC ON CO 28	LT NOT TAKING PLACE/PCRD TENSION ACTED	TENSION RELEASED	12:35:00	12:50:00	
7	CHP	cc 54	TRIPPED ON OLR	RESET DONE	08:00:00 08:15:00	08:10:00 08:20:00	
8	CHP	STK ON CC112	BC NOT RUNNING/	MPD TRIPPED ON SP FAULT/RESET DONE	06:20:00	06:35:00	
9	CHP	CC 32	TRIPPED ON OLR	RESET DONE	09:15:00	09:30:00	
10	CHP	SCR 9 ON CC104	SLEW NOT WORKING/MCCB TRIPPED	MCCB MADE ON	12:10:00	12:15:00	
11	CHP	SCR 7 ON CC40	BW and SLEW NOT WORKING/HYDROLIC RETURN FILTER BLOCK FEEDBACK MISSING	BYPASSEDAT I/O RACK	12:15:00	12:30:00	
12	CHP	CC 215	ZSS ACTED/CAGE GOT STUCKUP WITH MATERIAL	CAGE MADE FREE	12:05:00	12:20:00	
13	CHP	CC 29	ZSS ACTED/CAGE STUCKUP	MADE FREE	08:30:00	08:40:00	

वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 27/10/2026

Shift: A

Incharge(s): G Eswara Rao

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
14	CHP	TT NO CC 29	C/S ACTED	BYPASSED AT I/O RACK	09:10:00	09:15:00	AGAIN KEPT IN CKT
15	CHP	TT ON CC29	PCRD CBLE GOT CUT	CABLE RE JOINTED THEN GIVEN CLEARENCE	09:30:00	12:00:00	