



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 23/06/2026

Shift: A

Incharge(s): G Eswara Rao

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	WOBR ON CO 26	BC STOPPING ON ZSS/BYPASSED FOR DEMAND	ZSS KEPT IN CKT AFTER DEMAD	07:25:00	07:40:00	
2	OHP	WOBR ON CO 29	LUFFING NOT TAKING PLACE/PUMP OLR ACTED	RESET DONE/2TIMES	08:30:00 13:30:00	08:40:00 13:40:00	
3	OHP	TBS 2 ON CO 20	LBC NOT RUNNING/CHUTE JAMMING	INFORM TO OPERATION	11:45:00	12:00:00	
4	OHP	TBS 1 ON CO21	RBC ZSS ACTING/PROBE PROBLEM	ZSS PROBE REPLACED THEN TESTED OK	11:45:00	12:10:00	
5	OHP	TBS 6 ON CO 7A	LT NOT TAKING PLACE/M1 OLR ACTED	RESET DONE	08:15:00	08:25:00	
6	OHP	WOBR ON CO 29	BW NOT RUNNOING/OLR ACTED	RESET DONE	13:05:00	13:10:00	
7	OHP	CO 18	TRIPPED ON OLR	RESET DONE	11:45:00	12:00:00	
8	OHP	CO 76R	TRIPPED ON OLR/2TIMES	RESET DONE	11:45:00	12:00:00	
9	OHP	CO 18 TO CO23	FLAP GATE TRIPPED ON OLR	RESET DONE	08:10:00	08:20:00	
10	CHP	cc 203	tripped on olr /2times	reset done	10:05:00 10:45:00	10:15:00 10:50:00	
11	CHP	SCR 9 ONCC106	BC NOT RUNNING/COMMUNICATION PROBLEM	DIDNT FOUND ANY PROBLEM	09:10:00	09:20:00	
12	CHP	CC 201	PC ACTED	RESET DONE	11:30:00	11:40:00	



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 23/06/2026

Incharge(s): G Eswara Rao

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
13	WT	OP 2	FORWARD/REVERSE NOT TAKING PLACE/CASCADE RELAY CONTACT PROBLEM	CASCADE RELAY AUXARY BLOCK REPLACED THEN OK	06:30:00	06:45:00	